

Ref: BHE/PW/PUR/DHJRI-PIPG/1384/Clarification

Date 27/01/2015

To

ALL BIDDERS

Sub: Corrigendum-01: Clarification.

JOB:

TENDER NUMBER: BHE/PW/PUR/DJRI-PIPG/1384

Receipt Collection/Loading/Unloading/Transportation of materials from BHEL/client's stores/storage yard to site of work, erection, testing, commissioning, supply of paints/primer and application of paints for final painting, application of thermal insulation & sheeting/cladding work and handing over of complete **Power Cycle Piping / External Piping / Field Piping** together with valves, hangers and supports, fittings both **IBR piping** (carbon steel and alloy steel) and **non-IBR piping** (carbon & SS steel), complete with associated pipes, fittings and associated, accessories specialities and other accessories & equipments including bought out items etc for **Unit # 1, 2 & 3 of 3x90.3 MW RUPPL DMD Dahej** project at Reliance Utilities and Power Pvt. Limited (RUPPL), Dahej Taluka : Vagra, Dist- Bharuch, Gujarat

Bidders to kindly take note of the following:

AA) Clarification to the Queries of Bidder

SI No	Description / Bidder's query	BHEL's clarification
1	Refer Clause 7.2 and 7.4 of Annexure III of NIT 'Important Information' regarding Broad Terms and Conditions of Reverse Auction Please confirm that submission of on line sealed bid price by the bidder is to be the same as that quoted in the sealed price bid submitted to BHEL in hard copy or can be different.	Tender conditions are silent on this aspect. However bidders are advised to submit their most competitive rates at any point of time during tendering.
2	Refer Clause 2.22.2 and 2.24.1 of GCC, Please confirm the date of commencement of guarantee period	Date of commencement of guarantee period shall be 'End/Completion Date of work/contract certified by BHEL Site Engineer'
3	Refer clause no 18.2 to 18.9 of Chapter-XVIII: Preservative Paining' in Volume IA TCC: Referred Clauses is to be deleted as the same pertains to STG	Clause no 18.2 to 18.8 of Chapter-XVIII: Preservative Paining' in Volume IA TCC stands DELETED. However Clause no 18.9 shall prevail.
4	Refer clause no 2.1.1 of Chapter - II: Scope of Work' in Volume IA TCC: Appendix I (Weight Detail) & Appendix II (Summary of weight details) is not available in tender specification	Weight Detail and Summary of weight details are given in Annexure I (Page 52) and Annexure II (Page 54) of Volume IA TCC
5	Refer clause no 15.3.7 of Volume IA TCC:	Yes, electrodes and filler wire for P-91 welding shall be supplied by

Ref: BHE/PW/PUR/DHJRI-PIPG/1384/Clarification

Date 27/01/2015

	Whether electrodes and filler wire for P-91 welding is supplied by BHEL free of cost	BHEL free of cost
6	Refer clause no 3.9.1 (k) of Volume IA TCC: Since Gantry Crane is not to be provided by contractor, question of lying of tracks does not arise. Please confirm.	Since Gantry Crane is not to be provided by contractor, lying of tracks shall not be applicable.
7	Refer Clause 16 – Annexure I of Volume IA TCC: Please confirm that the site painting is to be carried out for uninsulated / unprotected metal surfaces only. Whether SS Piping to be painted	Painting is to be done as per painting scheme.
8	Refer clause no 9.10 of Volume IA TCC: Whether High Purity Nitrogen Gas is required for subject job.	High purity nitrogen gas (for purging of generator stator water system) is excluded from scope.
9	Refer clause no 2.1.1 of Volume IA TCC: Following Portion of the referred Clause stands DELETED: As far as possible welding shall be done with Orbital / automated welding machine. Bidders shall provide plan for automated pre-fabrication & installation of piping including welding and confirm mobilization of required equipment accordingly. Quoted price shall be inclusive of these aspects.	
10	Refer Chapter IV 'T&P's & MME to be deployed by Contractor', SI No 16 of Volume IA TCC: Orbital Welding Machine is NOT REQUIRED for this job. Hence all related clause of Orbital Welding Machine stands DELETED.	
11	Refer clause no 13.16 of Volume IA TCC: The least sentence of Clause 13.16 shall be read as "..... However, the contractor's quoted rate shall include fabrication and erection of all such platforms at site and no extra payment shall be allowed for this"	
12	Refer clause no 11.1.9 of Volume IA TCC: Following portion of the referred clause STANDS DELETED "Contractor may please note that the loading of materials at storage yard/Stores in contractor's Trailer / Carriers while collecting materials will be done by material handling agency deployed by BHEL"	

Ref: BHE/PW/PUR/DHJRI-PIPG/1384/Clarification

Date 27/01/2015

BB) Extension of Last Date

The last date for submission of Tender has been re scheduled to 03/02/2015, 15.00 hrs.

Technical Bid shall be opened on 03/02/2015 at 16.00 hrs

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1384)" against NIT-20193 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)