REQUEST FOR QUOTATION - ONLINE BIDDING



BHARAT HEAVY ELECTRICALS LIMITED

Electronics Division PB No. 2606, Mysore Road Bangalore - 560026 **INDIA**

RFQ NUMBER: NKRE000634

Due Date/Day: 12.09.2022 MON

Time : 13:00 HRS

(for all correspondence)

RFO DATE: 30.08.2022

Please submit your lowest quotation subject to our terms and conditions attached for

the material mentioned below. "Quotation to be submitted in E Procurement portal only"

Phone: 26998663

E-mail: nilmanikumar@bhel.in

Purchase Executive: Nilmani Kumar

Sl No.	Description	Qty	Unit	Delivery qty	Delivery Date
1	SN0659420147 PROFIBUS ITEMS FOR NABINAGAR 4X250MW FGD * HSN/SAC : 7607 Doc No PS4102099 Rev - 00 Test Certificate PROFIBUS ITEMS FOR NABINAGAR 4X250MW as per PS4102099.IO Quantities as per Annexure-II.	1	NO	1	24.10.2022
2	SN0659420155 PROFIBUS ITEMS FOR NABINAGAR 3X660MW FGD * HSN/SAC : 7607 Doc No PS4102099 Rev - 00 Test Certificate PROFIBUS ITEMS FOR NABINAGAR 3X660MW as per PS4102099. IO Quantities as per Annexure-I.	1	NO	1	24.10.2022
3	SN0659420163 PROFIBUS ITEMS FOR RAMAGUNDEM STI,II FGD * HSN/SAC : 7607 Doc No PS4102099 Rev - 00 Test Certificate PROFIBUS ITEMS FOR RAMAGUNDEM STG-I,II (3X200MW+3X500MW) as per PS4102099. IO Quantities as per Annexure-IV.	1	NO	1	24.10.2022
4	SN0659420171 PROFIBUS ITEMS FOR BHILAI 2X250MW FGD * HSN/SAC : 7607 Doc No PS4102099 Rev - 00 Test Certificate PROFIBUS ITEMS FOR BHILAI 2X250MW as per PS4102099. IO Quantities as per Annexure-III.	1	NO	1	24.10.2022

Total Number of Items -

1.

2.

NOTES:

- 1. This RFQ is governed by:
- a) INSTRUCTIONS TO BIDDERS/SELLERS and GENERAL CONDITIONS OF CONTRACT FOR PURCHASE available at http://edn.bhel.com (RFQ-PO Terms &

Conditions)

- b) Any other specific Terms and Conditions mentioned. of offers are required to furnish authorization letter for the same.
- 2. Tender Result can be viewed in the website.
- * The HSN/SAC no mentioned against the line items in the RFQ are indicative only.

For and On behalf of BHEL.

Nilmani Kumar Control Equipment



PRE-QUALIFICATIONS REQUIREMENT

TW/410/03

REV. NO. 00

PAGE 01 0F 4

A4 - 10

PRE-QUALIFICATIONS REQUIREMENT FOR PURCHASE OF FIELDBUS (PROFIBUS) SYSTEM COMPONENTS For FGD PROJECT

PROJECT

CONFIDENTIAL

COPY RIGHT AND

: FGD PROJECT

CUSTOMER

: M/s NTPC

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY. CHECKED BY APPROVED BY S B BANIK **ISSUED** DATE 410 22/08/2022 **ENGG** RAVI KUMAR POGIRI



THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY.

COPY RIGHT AND CONFIDENTIAL

PRE-QUALIFICATIONS REQUIREMENT

REV. NO. 00	TW/410)/03		
	REV. N	10.	00	\$ Y

REVISION HISTORY SHEET

REV NO.	DATE	NATURE OF CHANGE	REASON	PREPAR ED BY	CHKD BY	APPROVED BY
00	22/08/2022	FIRST ISSUE		DP /RKP	MK	SBB
			12	:		
	_					,
					1740	

	277 * * * * * * * * * * * * * * * * * *	CHECKED BY	AF	PROVED BY
		MUKESH KUMAR	1	S B BANIK
ę		DINAKARAPUWW	ISSUED 410	DATE
		RAVI KUMAR POGIRI	ENGG	22/08/2022

4 A4 - 10

PRE-QUALIFICATIONS **REQUIREMENT**

TW/410/03 **REV. NO. 00** PAGE 03 0F 04

Pre-Qualification Requirements (PQR) of Bidders for FIELDBUS (PROFIBUS) BASED COMMUNICATION COMPONENTS as a part of offer as per PURCHASE **SPECIFICATION PS4102099**

- 1. The bidder should have designed, manufactured, supplied FIELDBUS (PROIFIBUS) BASED COMMUNICATION COMPONENTS for either any power plant or any process industry satisfying the IEC61158 standard for Profibus communication.
- 2. The FIELDBUS (PROIFIBUS) BASED COMMUNICATION COMPONENTS should have formed part of any process control loop of power plant/process industry.
- 3. Further the components being offered should have been in successful operation for at least one year prior to the date of opening of techno-commercial bid.
- 4. Vendor shall submit the proven Performance Track Record (PTR) for the model offered by them and also submit satisfactory performance certificates for at least one year as on date of opening of bid from minimum one end user of a power plant or any process industry.
- 5. Along with the documents related to PQR above, following details shall also be submitted included in the Offer:
 - Technical literature / Manuals of offered system I.
 - Unpriced Purchase Order copies
 - Reports of successful commissioned systems of the offered components / Minutes of the meetings with the end user.
- 6. Vendor should necessarily have Indian branch office or Indian representative for support of Erection & Commissioning and after sales service, with Organization chart. Name & registered address of the details of Manufacturing, testing & inspection facility.
- 7. Bidder shall have facility in India for Engineering activities, preparation of Documents, Servicing of offered system, Stocking of Spares..etc.. Submit these details.
- 8. Bidder shall submit following Type Test Report for Solid state/ Electronic Cards of offered components.
 - I. Surge withstanding capacity (SWC) as per ANSI 37.90.1/IEEE-472/Suitable class of EN 61000-4-12 which is equivalent to ANSI 37.90.1/IEEE-472.
 - II. Dry Heat test as per IEC-68-2-2 or equivalent.
 - III. Damp Heat test as per IEC-68-2-3 or equivalent.
 - IV. Vibration test as per IEC-68-2-6 or equivalent.
 - ٧. Electrostatic discharge tests as per EN 61000-4-2 or equivalent.
 - VI. Radio frequency immunity test as per EN 61000-4-6 or equivalent.
 - VII. Electromagnetic Field immunity as per EN 61000-4-3 or equivalent.

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY. CONFIDENTIAL COPY RIGHT AND



बिएचई एल
A4 - 10

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY.

COPY RIGHT AND CONFIDENTIAL

PRE-QUALIFICATIONS REQUIREMENT

TW/410/03
REV. NO. 00
PAGE 04 0F 04

Important note: In case Bidder does not submit details mentioned in above clauses or meet the requirements of Pre-qualification requirements, Offers will be summarily rejected and bidder's technical offers/proposals will not be evaluated.



PS/410/2099

REV: 01

PAGE 1 OF 25

PROJECTs:-

COPY RIGHT AND CONFIDENTIAL

- NABINAGAR (3X660MW) FGD (a)
- (b) NABINAGAR (4X250MW) FGD
- (c) BHILAI (2X250MW) FGD
- RAMAGUNDEM STG-I,II (3X200MW, 3X500MW) FGD (d)

TECHNICAL SPECIFICATION **FOR PURCHASE OF** FIELDBUS (PROFIBUS) SYSTEM COMPONENTS For FGD PROJECT

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICAL LIMITED.
IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANYWAY DETERMINED TO THE INTEREST OF THE
COMPANY **REVISION:01 APPROVED** S B BANK ISSUED DATE 410 22/08/2022 MUKESH KUMAR



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099

REV: 01

PAGE 2 OF 25

REVISION HISTORY SHEET

REV No.	DATE	NATURE OF CHANGE	REASON	PREPD BY	CHKD BY	APRVD BY
00	12/08/2022	FIRST ISSUE		DP/RKP	MK	SBB
01	22/08/2022	SECOND ISSUE	General Revision	DP/RKP	MK	SBB
						-
	3				3 3 1	

REVISION:01	APPROVED S B BANIK	9	
	DINAKARA POGIRI MUKESH KUMAR	ISSUED 410	DATE 22/08/2022



PS/410/2099

REV: 01

PAGE 2 OF 25

REVISION HISTORY SHEET

REV No.	DATE	NATURE OF CHANGE	REASON	PREPD BY	CHKD BY	APRVD BY
00	12/08/2022	FIRST ISSUE		DP/RKP	MK	SBB
01	22/08/2022	SECOND ISSUE	General Revision	DP/RKP	MK	SBB

COPY RIGHT AND CONFIDENTIAL
THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICAL LIMITED.
IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANYWAY DETERMINED TO THE INTEREST OF THE
COMPANY APPROVED **REVISION:01 S B BANIK PREPARED CHECKED ISSUED** DATE 22/08/2022 410 **DINAKARA P** RAVI KUMAR POGIRI MUKESH KUMAR

बी एच ड एल **मिम्मि** A4-11

PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099

REV: 01

PAGE 3 OF 25

CONTENTS

SI. No	Description	Reference	Sheet
1	Scope of Supply	PS/ 410/ 2099	4 to 5
2	Technical Requirement	PS/ 410/ 2099	6 to 15
3	Profibus transmitter list for calculation of Profibus components/ modules	PS/ 410/ 2099	16 to 23
4	Exclusion	PS/ 410/ 2099	24



PS/410/2099

REV: 01

PAGE 4 OF 25

Scope of Supply

This specification is bifurcated in two broad sections, one is the "Standard Section and another is "Project specific section-Annexure-I ,II , III & IV" which can vary project to project.

The scope of supply for **PROFIBUS** system components /modules as follows.

S1. No	Project	Main supply Qty including additional 5% spare of total Qty	Mandatory spares Qty (20% or 2 nos subject to max 40 nos)	Technical services
1	NABINAGAR 3X660MW FGD	TO BE CALCULATED BASED ON ANNEXURE -I	As per clause- 3.2 of Tech spec.	As per clause- 9.1 of Tech spec.
2	NABINAGAR 4x250MW FGD	TO BE CALCULATED BASED ON ANNEXURE -II	-do-	-do-
3	BHILAI 2X250MW FGD	TO BE CALCULATED BASED ON ANNEXURE -III	-do-	-do-
4	RAMAGUNDAM STG-I&II (3X200MW, 3X500MW)	TO BE CALCULATED BASED ON ANNEXURE -IV	-do-	-do-

Technical Conditions.

- 1. In case of any query on the Technical matter w.r.t. BHEL Specification, Bidder shall contact BHEL, within 1 week of receipt of Enquiry for seeking clarifications. This shall not be used for seeking bid submission due date extension. No query will be entertained after Bid submission is completed.
- 2. Offers with incomplete information will not be considered for evaluation and are likely to be rejected outright without any further interaction with the Bidder.
- 3. After Bid submission, in case Bidder proposes Unsolicited Tender Modifications such as typographical mistakes etc., such modifications will not be considered for evaluation.



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099	_
REV: 01	_
PAGE 5 OF 25	_

4. Superior Technical features proposed if any by the Bidder, over & above BHEL enquiry specification requirements cannot be given any special preference w.r.t. price, delivery and comparison with other Bidders.

5. No Deviations are permissible. Any deviations proposed by the bidder, shall be considered withdrawn, without claiming any commercial implications.

- 6. In case of contradiction between any specification clause, vendor shall bring to BHEL's notice and BHEL's decision in this regard shall be final and binding. In the event of conflict, most stringent requirements shall be followed in general.
- 7. Vendor shall give clause wise compliance to all the clauses of this main specification along with sub-specifications for individual items. Otherwise it is presumed that supplier is fully complying with the specifications. Deviations/clarifications are not allowed after placement of P.O. (Purchase Order).
- 8. If any defect in the material during manufacturing process, transportation activities etc, Vendor is sole responsible for the replacement with in a period of 3 weeks from the supply/identified as defective.
- 9. Vendor to consider multiple site-visits for Erection supervision and commissioning for each unit based on site readiness/customer requirements for the offered package on lump sum basis. Due to urgency of a project if the material supplied for one project is utilized in another project the terms and condition for warranty of material, services will remain unchanged and applicable to project under execution.



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 6 OF 25

Technical Requirement

A: Standard Section

1. GENERAL

The purpose of this specification is general technical requirement for procurement of **PROFIBUS system components** / **modules.** This specification specifies broadly the requirement of Design, Engineering, Manufacturing, Testing of various components at vendor works. The items pertaining to control room shall be mounted in BHEL-DCS panel and the field items shall be mounted in the field. Vendor to provide supervision during engineering, testing, FAT, Erection and Commissioning, site acceptance of integrated Test (SAT) and protocol to be signed with end customer.

The FIELDBUS (PROFIBUS PA protocol) based I/O modules of proven technology PROFIBUS PA protocol complying to IEC 61158 to be supplied by the vendor. This includes all remote I/O modules, power supplies, communication module, housing for remote I/O modules, diagnostic software and any other component, modules etc. not specifically mentioned but required to make the system complete for meeting the requirements specified here in.

The proposed items shall be installed in Safe Zone of power plants for which BHEL is supplying main control system. The project names and scope are as per "Project specific section" in Annexure-I, II,III & IV.

2. a. FIELDBUS (PROFIBUS) I/O SYSTEM TECHNICAL DETAILS

This specification covers broadly the requirement of FIELDBUS (PROFIBUS) based system component / modules with any 6/12/16 - segment protector , Segment Motherboard, Advanced Diagnostic Module, Fieldbus Power Hub, Gateway Motherboard, Gateway Module, Link cable between gateway motherboard and Power Hub motherboard., Surge Protector with base for field and control room, Stainless Steel(SS) JB (as per 2.b) along with Segment Protector mounted inside , Software user interface for Advanced Diagnostic Modules, configuration PC (Laptop) and any other component not specifically mentioned but required to make the system complete. It is the responsibility of the vendor to ensure that all the components other than those mentioned in **Annexure -V(Exclusion)** are considered in the offer to make the system complete.



PS/410/2099 REV: 01

PAGE 7 OF 25

System shall be capable to acquire signals from PA device like Pressure transmitter, Diff Pressure Transmitter, Temperature Transmitter, Flow Transmitter etc. Details of total signals are attached as Annexure-I,II,III & IV as per the projects mentioned.

These PA devices shall be terminated in Field Junction Box housing 6/12/16 channel Segment Protector, Surge protector and terminator. All these Field components shall have operating Temperature range from 0-70 Deg C or better. Other Communication components shall be housed in a control panel located in control room. All these Control Room components shall have operating Temperature range from 0-60 Deg C or better

All Gateways, Power supplies, Power conditioners, diagnostic module, surge suppressors etc. shall be DIN rail mountable.

The proposed items will be connected to BHEL's controller as master through interface module located in main control room. All communication cable from field and control room mounted panels are in the scope of BHEL however the vendor shall supervise the engineering of cabling and proper distribution to meet the intent of specification requirement. Location of field Mounted items and Control room mounted are mentioned in Annexure – I, II, III & IV depending on the projects mentioned.

2.b Profibus SS JB IP66 with Field Items

Profibus Stainless Steel JB IP66 & below Technical Requirements:

Material of JB: SS316L, Thickness of material: 1.5mm

Protection Class: IP66 or better

Type of JB: Standard Hinge type with lockable door on front side.

SS TAG plate fitted on the door with Tagnames engraved (It is the responsibility of

the bidder to obtain Tagnames from Purchaser before Manufacturing)

Finish: Electro polished (outside)

Protection Class: IP66 or better Materials to be fitted inside

JB: Profibus Segment protectors (suitable for connecting upto 16 devices), Profibus Surge protector, Profibus terminator, other accessories as required by vendor for system completion.

Glands & Plugs: Suitable SS glands and Blind Plugs to be provided in JB. (Additionally Blind Plugs to be provided loose on over-all basis, Qty shall be 20% of total mounted cable gland)

Junction Box to be complete with all the materials mounted in the JB and internal wirings done of the materials fitted.



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 8 OF 25

3. SPARE REQUIREMENT

- 3.1 Offered items shall be expandable. Various in-built spare capacity shall be calculated based on requirement in annexure-I, II, III and IV depending on the projects as mentioned.
 - I. Segment Spare capacity: 40%
 - II. 5% components on overall basis (This also includes Segment protectors, Surge protector with base and Terminator mounted inside JB)

3.2 Mandatory Spare quantities,

Apart from the required qty, for all items of Fieldbus system (including field accessories): -

20% or 2 Nos. of each type, model and rating whichever is more subject to maximum of 40 nos of each type.

NOTE: All mandatory spares items shall be quoted with Unit price along with required quantities, as per spec.

4. SYSTEM REQUIREMENT

Offered system shall be of latest proven technology. Vendor to submit, for the offered system's reference list and operating experience of the listed services in thermal power plants/any other industries, for more than 1 years with similar kind of application. Any other reference letters from the user of the system/any other industry etc. may also be submitted for information. Operating experience / reference list of Individual components forming the whole system may also be furnished. All field mounted components in offered system shall meet following requirements, as minimum



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 9 OF 25

- i. Compatibility with Profibus based Field Instruments : Press Txr, Diff Pr Txr, Temp Txr, Flow Txr ,Level Txr
- ii. Operating Temperature**: 0-70 Deg C or better (continuous operation)
- iii. Diagnostics: Wire Break monitoring, Power supply healthiness etc.
- iv. Mounting: DIN Rail Mounting
- v. Accessories : All required Accessories to make the system complete , shall be provided
- vi. EMC: EN61326 Standard.

** Control room mounted equipment shall be suitable for operating temperature up to 60 Deg C or better. (continuous operation) with all requirements of latest version of standards for FIELDBUS (PROFIBUS) viz. IEC 61158. All required libraries to execute various tasks like the design of fieldbus interfacing scheme, from field to Controller shall comply data acquisition, control/protection etc shall be provided. Redundant host/ master card and redundant power supply along with diagnostic module shall be provided.

Vendor to provide Fieldbus devices specifications (maximum current drawn from bus, block execution speeds, power conditioner suitable for field barrier, etc.)

Vendor to provide all standard functional blocks for all FIELDBUS (PROFIBUS) devices as per latest FIELDBUS (PROFIBUS) version and standard guidelines for engineering by purchaser. Fieldbus components including power supply, terminators, isolators, etc. provided by vendor shall comply to IEC 61158 and other standard Fieldbus guidelines.

Redundant host/ master card and redundant power supply along with advance diagnostic module shall be provided. All required libraries to execute various tasks like data acquisition, control/protection etc. shall be provided.

5. **QUALITY REQUIREMENT**

The items covered under this specification shall be subject to vendor's Quality Plan to be approved by M/s BHEL/ End user before start of manufacture. To ensure that quality is in-built in each equipment the Quality Assurance System



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

submitted to purchaser for his review along with the offer.

PS/410/2099

REV: 01

PAGE 10 OF 25

manual & Quality Plan indicating the system followed by the vendor shall be

The vendor shall give at least 15 days written advance notice to purchaser for witnessing the tests/inspection at various stages. The expenses for all such test/inspection shall be to Manufacturer's account except for the expenses of purchaser's representatives witnessing the test. The purchaser shall attend such test/inspection or advice that the manufacturer may proceed with the test, which shall be deemed to have in purchaser's presence and shall furnish relevant test result and test certificates to the purchaser for his review who will then issue Material Dispatch Clearance Certificate (MDCC) enabling supplier to dispatch the equipment.

6.0 TYPE TEST REQUIREMENT:

The Vendor shall give the type test report for the offered items and the test requirement shall cover CMRR, NMRR Verification. Submission of type test results and certificate shall be acceptable provided.

- i) The same has been carried out by the Vendor on exactly the same model / rating of equipment.
- ii) There has been no change in the components from the offered equipment & tested equipment.
- iii) The test has been carried out as per the latest standards along with amendments as on the date of Bid opening and as indicated below:

SPECIAL REQUIREMENT FOR SOLID STATE EQUIPMENTS/ SYSTEMS

The minimum type lest reports, which are to be submitted for each of the major C&I systems shall be as indicated below:

i) Surge Withstand Capability (SWC) for Solid State Equipment Systems All solid state systems/equipment shall be able to withstand the electrical noise and surges as encountered in actual service conditions and inherent in a power plant. All the solid state systems/equipment shall be provided with all required protections that needs the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472.Hence, all front end cards which receive external signals like Analog input & output modules. Binary input & output modules etc. including power supply, data highway



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 11 OF 25

data links shall be provided with protections that meets the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472. Complete details of the features incorporated in electronics systems to meet this requirement, the relevant tests carried out, the test certificates etc. shall be submitted along with the proposal.

As an alternative to above, suitable class of EN 61000-4-12 which is equivalent to ANSI /37.90.1/IEEE-472 may also be adopted for SWC test.

- ii) Dry Heat test as per IEC-68-2-2 or equivalent.
- iii) Damp Heat test as per IEC-68-2-3 or equivalent.
- iv) Vibration test as per IEC-68-2-6 or equivalent.
- v) Electrostatic discharge tests as per EN 61000-4-2 or equivalent.
- vi) Radio frequency immunity test as per EN 61000-4-6 or equivalent.
- vii) Electromagnetic Field immunity as per EN 61000-4-3 or equivalent.


Test listed at item no. v, vi, vii, above are applicable for electronic cards only as defined under Item(i) above.

Note: If Type Tests and other tests (as specified under 6.0) have been conducted with reference to standards different than what have been specified in the specification, then vendor to clearly indicate these specification with equivalent specifications in the offer.

7.0 CONFIGURATION & DIAGNOSTIC SOFTWARE

1.0 All software required for configuration of the offered FIELDBUS (PROFIBUS) system shall be considered and offered. Similarly, software for Diagnostics /Troubleshooting is also to be part of offer. Any license, if required, to be considered on Project/Site basis and not on Unit basis. System Configuration PC (Laptop) required to load these software will be provided by purchaser. Configuration of PC (Laptop) shall be carried out by vendors with latest configuration software with all the required basic software/operating system. All these software along-with necessary device description files to be supplied in CD or any other storage media only, even though it may be available in Supplier's Web Site or otherwise. Any cable required for communication during configuration also be considered in the offer.

Supplier to provide all necessary technical support to establish communication between the offered system and BHEL's control system during FAT at





PS/4	10/2	099		
REV:	01			
PAGE	12	OF	25	

purchaser works and during commissioning at project site. Any software OR Configuration file etc. required for establishing meaningful communication shall be part of the Offered system

8.0 WARRANTY

The offered items shall be guaranteed for satisfactory operation of 18 months from the date of commissioning OR 24 months from the date of supply whichever is earlier.

All the products / components quoted for this tender shall carry three years warranty after the completion of the above period.

Equipment will be at BHEL/EDN for a period of two/three months for configuration and project engineering/demonstration to end customer. Subsequently it will be sent to respective project as mentioned in Annexure-I ,II III & IV depending on the projects as mentioned.

9.0 ENGINERING, TESTING, ERECTION & COMMISSIONING (Technical services) SCOPE

9.1 Technical services:

Α	Technical Services to be provided at BHEL/EDN, Bangalore.	* One Visit per project
В	Technical Services to be provided at Project location within India as per Annexure-I,II,III & IV as per projects site.	* Unit wise Visits

^{*}Each visit is considered as minimum five working days.

Vendor to quote for Slno –A & B

NOTE: All Technical services shall be quoted with per project separate Lump-sum price in the offer.

9.2 Vendor has to depute their Engineer to BHEL-EDN during detailed engineering & FAT to establish communication with Host DCS system etc. Vendor to indicate per unit separate Lump-sum price for this activity in the offer as mentioned in clause 9.1



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 13 OF 25

9.3 Vendor has to depute their Engineer to Project site located within India. Project details will be indicated by BHEL along with PO. Site visit should be inclusive of travel, stay and other expenses of vendor personnel. Vendor has to complete the activity by demonstration, documentation and making MOM with Customer / BHEL

site Engineers. Vendor to indicate per unit separate Lump-sum price for this activity

10.0 TRAINING

in the offer as mentioned in clause 9.1

<u>Pre-engineering</u>: The Vendor shall provide training separately to employer's personnel and also separately to the end customer personnels on following aspects of fieldbus (i) Hardware & Software features (ii) System design, diagnostic and testing (iii) maintenance, troubleshooting and fault analysis. This training shall be provided by certified training personnel of Profibus foundation and it shall be provided before approval of basic design and engineering document.

On Site: Vendor to provide Two days on-site training per unit to BHEL and End User's engineers on all aspects of the FIELDBUS (PROFIBUS) system being offered/supplied. Tentatively 10-15 Engineers will participate in this training. Training shall necessarily include Technical details of FIELDBUS (PROFIBUS) system, Operating principle, system configuration supplied, system trouble-shooting and maintenance, as minimum requirement

11.0 DOCUMENTATION

11.1 Documents to be furnished along-with offer (1 set)

- Technical write-up(functional)
- > Technical literature/catalog of each component
- ➤ Configuration drawing/Segment design including power supply and monitoring scheme.
- Detailed bill of material with make & model
- > Data sheet of each component offered
- Clause-wise confirmation/deviation list
- Reference List/Operating experience
- Quality Plan
- List of Software to be supplied
- > Calculation considering various distances between different components.
- Clear list of items/software etc. NOT CONSIDERED but required to complete the system



PS/410/2099 REV: 01

PAGE 14 OF 25

11.2 Documents to be furnished after placement of order (for Approval by BHEL/ End User- 2 sets hardcopies + soft copy in PDF format) Technical write-up(functional)

- Technical literature/catalog of each component
- Configuration drawing/segment design
- > Detailed bill of material with make & model
- Data sheet
- Quality Plan
- > List of Software to be supplied
- > Type test reports for the Tests mentioned under clause 6.0

11.3 Final Operation & Maintenance Manual (O&M Manual) shall contain minimum of following:

- Technical write-up(functional)
- > Technical literature/catalog of each component
- Configuration drawing/segment design
- Detailed bill of material with make & model
- Data sheet
- Schematic diagram/Loop diagram including Termination details
- > Details of Software being supplied
- Trouble shooting procedure and Maintenance guidelines
- ➤ O&M Manuals to be submitted at the Time of Dispatch. (2 sets hardcopies + 1 soft copy in .PDF format)

NOTES:

a. Vendor must furnish, all documents, in line with specification along with offer. Clause-wise specific acceptance/deviations shall be furnished. Deviations, if any, must be clearly brought out in offer. Failure to provide Clause-wise acceptance/deviations may result in Technical disqualification.

ब एच ई एल **मिम्नि A4-11**

PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 15 OF 25

- b. It is the responsibility of vendor to check for completeness of the offered system. If any additional component/software etc. is required during Engineering/Testing/Erection & Commissioning then same to be provided by the Vendor other than mentioned in exclusion IN Annexure-V with NO EXTRA COST TO BHEL.
- c. If the Vendor is supplying the Quoted components to BHEL-Electronics Division for the first time then the Vendor has to validate the offered components with BHEL-DCS system by providing one set of each components on returnable basis at BHEL-Electronics division within 15 days of Technical Bid opening failing which the Technical Offer shall be rejected. The cost arising out of providing the components to be borne by vendor.
- d. Any clarification required from BHEL side may be obtained during offer stage only.



PS/410/2099

REV: 01

PAGE 16 OF 25

ANNEXURE – I (APPLICABLE NABINAGAR 3X660MW FGD)

B. Project specific section

All components to be calculated based on the number of devices and

SLNO	PROJECT	LOCATION Number of PA devices				DCS CONTROLLER	
	NAME					NAME	
			UNIT-1	UNIT-2	UNIT-3		
	NABINAGAR						
	3X660MW						
01		101	8	8	8	AP01	
		103	36	36	36	AP01	
		105	17	17	17	AP01	
		107	50	50	50	AP01	
		108	28	28	28	AP01	
		109	11	11	11	AP01	
	TOTAL		150	150	150		
02		102	8	8	8	AP02	
		104	36	36	36	AP02	
		105	4	4	4	AP02	
		106	5	5	5	AP02	
		107	72	72	72	AP02	
		108	24	24	24	AP02	
		109	11	11	11	AP02	
	TOTAL		160	160	160		
	•	СОМ	MON SYS	TEM	l .		
03		2		12		ZP01	
		15		9		ZP01	
		17		19		ZP01	
		21		24		ZP01	
	TOTAL			64			
	1						
04		3		6		ZP02	
		7		6		ZP02	
		11		5		ZP02	
		16		5		ZP02	
		18		19		ZP02	
		20		24		ZP02	
	TOTAL			65			



PS/410/2099

REV: 01

PAGE 17 OF 25

I-11 PAC

05		6	6	ZP03
		8	4	ZP03
		9	4	ZP03
		10	4	ZP03
		12	5	ZP03
	TOTAL		23	
06		2	21	ZP04
07		3	21	ZP05
80		6	20	ZP06
				·
09		6	56	ZP07

Total Instruments in NABINAGAR 3X660MW FGD = 1200



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 18 OF 25

ANNEXURE – II (APPLICABLE NABINAGAR 4X250MW FGD)

B. Project specific section

All components to be calculated based on the number of devices and based on spare philosophy as mentioned in clause no 3.

based on spare philosophy as mentioned in clause no 3.									
SL	PROJECT	LOCATION	Nı	umber of	PA device	ces	DCS		
NO	NAME						CONTROLLER		
			UNIT-1	UNIT-2	UNIT-3	UNIT-4	NAME		
	NABINAGAR								
	4X250MW								
01		101	8	8	8	8	AP01		
		103	36	36	36	36	AP01		
		105	17	17	17	17	AP01		
		107	50	50	50	50	AP01		
		108	28	28	28	28	AP01		
		109	11	11	11	11	AP01		
	TOTAL		150	150	150	150			
02		102	8	8	8	8	AP02		
		104	36	36	36	36	AP02		
		105	4	4	4	4	AP02		
		106	5	5	5	5	AP02		
		107	72	72	72	72	AP02		
		108	24	24	24	24	AP02		
		109	11	11	11	11	AP02		
	TOTAL		160	160	160	160			
		(COM M ON	SYSTEM					
03		2		•	12		ZP01		
		15			9		ZP01		
		17			19		ZP01		
		21		2	24		ZP01		
	TOTAL			(64				
	1	l							
04		3			6		ZP02		
		7			6		ZP02		
		11			5		ZP02		
		16			5		ZP02		
		18		•	19		ZP02		
		20		2	24		ZP02		
	TOTAL				35				
	IOIAL						<u> </u>		



PS/410/2099

REV: 01

PAGE 19 OF 25

ZP07

05 6 6 ZP03 8 4 ZP03 9 4 ZP03 10 4 ZP03 12 5 ZP03 TOTAL 23 06 2 21 ZP04 07 3 21 ZP05 80 20 ZP06 6

56

Total Instruments in NABINAGAR 4X250MW FGD = 1510

6

COPY RIGHT AND CONFIDENTIAL
THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICAL LIMITED.
IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANYWAY DETERMINED TO THE INTEREST OF THE
COMPANY

09



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099	
REV: 01	

PAGE 20 OF 25

ANNEXURE – III (APPLICABLE BHILAI 2X250MW FGD)

B. Project specific section

All components to be calculated based on the number of devices and based on spare philosophy as mentioned in clause no 3.

SLNO		LOCATION	Number o	of PA devices	DCS Controller
	NAME		UNIT-1	UNIT-2	NAME
	BHILAI 2x250MW				
01		101	8	8	AP01
		103	36	36	AP01
		105	17	17	AP01
		107	50	50	AP01
		108	28	28	AP01
		109	11	11	AP01
	TOTAL		150	150	
02		102	8	8	AP02
		104	36	36	AP02
		105	4	4	AP02
		106	5	5	AP02
		107	72	72	AP02
		108	24	24	AP02
		109	11	11	AP02
	TOTAL		160	160	
		COM	MON SYSTEM	Л	
03		2		12	ZP01
		15		9	ZP01
		17		19	ZP01
		21		24	ZP01
	TOTAL			64	
04		3		6	ZP02
<u> </u>		7		6	ZP02
		11		5	ZP02
		16		5	ZP02
		18		19	ZP02
		20		24	ZP02
	TOTAL	20		65	



PS/410/2099

REV: 01

PAGE 21 OF 25

ZP06

ZP07

05 6 ZP03 6 8 4 ZP03 9 ZP03 4 10 4 ZP03 12 5 ZP03 TOTAL 13 06 2 21 ZP04 07 3 21 ZP05

11

56

Total Instruments in BHILAI 2X250MW FGD = 890

6

6

COPY RIGHT AND CONFIDENTIAL
THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICAL LIMITED.
IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANYWAY DETERMINED TO THE INTEREST OF THE
COMPANY

80

09



PURCHASE SPECIFICATION FOR PROFIBUS COMPONENT FOR FGD PROJECTS

PS/410/2099 REV: 01

PAGE 22 OF 25

ANNEXURE – IV (APPLICABLE RAMAGUNDAM 3X200MW + 3X500MW FGD)

B. Project specific section

All components to be calculated based on the number of devices and based on spare philosophy as mentioned in clause no 3.

SL	PROJECT NAME	LOCATION	1	lumber of	PA devic	es	DCS CONTROLLER NAME
NO		3X200 MW UNIT-	3X200 MW UNIT- 1,2,3	500MW UNIT-4	500MW UNIT-5	500MW UNIT-6	
	RAMAGUND AM 3X200MW + 3X500MW						
01		101	8	8	8	8	AP01
		103	36	36	36	36	AP01
		105	17	17	17	17	AP01
		107	50	50	50	50	AP01
		108	28	28	28	28	AP01
		109	11	11	11	11	AP01
	TOTAL		150	150	150	150	
02		102	8	8	8	8	AP02
		104	36	36	36	36	AP02
		105	4	4	4	4	AP02
		106	5	5	5	5	AP02
		107	72	72	72	72	AP02
		108	24	24	24	24	AP02
		109	11	11	11	11	AP02
	TOTAL		160	160	160	160	
			COM M OI	N SYSTEM			
03		2			12		ZP01
		15			9		ZP01
		17			19		ZP01
		21		2	24		ZP01
	TOTAL				64		



PS/410/2099

REV: 01

PAGE 23 OF 25

ZP02 ZP02 ZP02 COPY RIGHT AND CONFIDENTIAL
THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICAL LIMITED.
IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANYWAY DETERMINED TO THE INTEREST OF THE
COMPANY ZP02 ZP02 **TOTAL** ZP03 ZP03 ZP03 ZP03 ZP03 **TOTAL** ZP04 ZP05 ZP06 ZP07

Total Instruments in RAMAGUNDAM 3X200MW + 3X500MW FGD = 1510



PS/410/2099 REV: 01

PAGE 24 OF 25

ANNEXURE-IV

EXCLUSION FROM VENDOR'S SCOPE

SLNO	DESCRIPTION	REMARKS
1	Fieldbus cable from field JB to field device.	
2	Cable between control room panel and field JB	
3	Cable between BHEL Master controller to DP/PA coupler.	
4	Profibus OLM - Multimode Glass Fiber	
4	Profibus OLM - Multimode Glass Fiber	



PURCHASE SPECIFICATION FOR PROFIBUS

PS/410/2099

	HĦĦ	COMPONENT FOR FGD PROJECTS	REV: 01	
	A4-11		PAGE 25 OF 25	
THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICAL LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANYWAY DETERMINED TO THE INTEREST OF THE COMPANY		INTENTIONALY LEFT BLANK		