

## **PERFORMANCE GUARANTEES AND SCHEDULE OF GUARANTEES**

### **SCHEDULE OF GUARANTEES:**

All performance tests shall be carried out in accordance with the relevant latest international codes/standards.

### **CATEGORY – I GUARANTEES:**

Sl. No	Description	Data
1.	Guaranteed auxiliary power consumption (equipment's to be considered for power consumption is as per 18.1 of this technical specification) at rated capacity in KW. Bidder shall furnish Break-up among list of equipment's considers which is subjected to approval.	<b>Bidder to Provide (Vendor To fill table furnished in Pg 2 of this annexure).</b>

### **CATEGORY – II GUARANTEES:**

Sl. No	Description	Data
1.	Rated capacity of Wet Ball Mill (WBM) TPH at rated Limestone output fineness. <i>Contractor shall demonstrate the above capacity with the originally installed grinding elements in nearly worn-out condition as mutually agreed for the purpose of ascertaining wear life of any of the wear parts</i>	<b>54.6 TPH @ ≥90% through 325mesh.</b>
2.	Life of WBM wear parts <i>Contractor shall demonstrate the life of wet ball Mill wear parts in line with requirements stipulated in chapter -9(Design and construction of mill and accessories) of the Technical Specification. The establishment of the above guarantee shall be based on the operating records available at the Power station and will be computed for each pulverizer based on actual total hours of operation.</i>	<b>≥ 8,000 hours</b>
3.	Guaranteed ball consumption <i>Contractor shall guarantee ball consumption per ton of limestone throughput in line with requirements stipulated in chapter - 9(Design and construction of mill and accessories) the Technical Specification. Contractor shall furnish the minimum ball diameter below which the balls shall be replaced.</i>	<b>Bidder to Provide (≤700 grams/Ton of ground limestone)</b>
4.	Noise level at a distance of 1.0 meter from the equipment at site and 1.5 m above operating floor. Noise measurement shall be carried out as using applicable and international standards.	<b>≤ 90 dB A(for ball mill) ≤85 dB A(for other equipment's)</b>

### **OTHER GUARANTEES:**

Sl. No.	Description	Data
1.	Maximum vibration (peak to peak amplitude at site) microns	<b>Bidder to Provide</b>
2.	Scheduled Maintenance (Minor Overhauls): Recommended intervals between maintenance outages	<b>≥ 25,000 hours</b>
3.	Scheduled Maintenance (Major Overhauls): Recommended intervals between maintenance outages	<b>≥ 75,000 hours</b>
4.	Equipment Availability (%) Continuous for 180 days	<b>Bidder to Provide</b>

**Power consumption details**  
**(VENDOR TO FILL)**

**HT MOTORS**

Description	Guaranteed Shaft Power	Motor power considering motor efficiency as 95%.	Motor Rating & RPM
<b>Mill Motor*</b>			

\*T- S curve to be attached along with offer.


**LT MOTORS**


Description	Guaranteed Motor power	Motor Rating & RPM


**Total power consumptions to be guaranteed by vendor = Shaft power of HT motors + Sum of all motor powers for LT motors.**


**SUB-SECTION-VI**

**FUNCTIONAL GUARANTEES & LIQUIDATED DAMAGES**

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
<p><b>1.00.00</b></p> <p><b>2.00.00</b></p> <p>2.01.00</p> <p>2.01.01</p> <p>2.01.02</p> <p>2.01.03</p> <p>2.01.04</p> <p>2.01.05</p> <p>2.01.06</p>	<p><b>FUNCTIONAL GUARANTEES, LIQUIDATED DAMAGES FOR SHORTFALL IN PERFORMANCE AND PERFORMANCE GUARANTEE TESTS</b></p> <p><b>GENERAL</b></p> <p>The term “Performance Guarantees” wherever appears in the Technical Specifications shall have the same meaning and shall be synonymous to “Functional Guarantees”. Similarly the term “Performance Tests” wherever appears in the Technical Specifications shall have the same meaning and shall be synonymous to “Guarantee Test(s)”.</p> <p><b>PERFORMANCE GUARANTEES / PERFORMANCE TESTS</b></p> <p><b>General Requirements</b></p> <p>The Contractor shall guarantee that the equipment offered shall meet the ratings and performance requirements stipulated for various equipment covered in these specifications.</p> <p>The guaranteed performance parameters furnished by the Bidder in his offer, shall be without any tolerance values whatsoever. All margins required for instrument inaccuracies and other uncertainties shall be deemed to have been included in the guaranteed figures. No tolerance or allowance on the test result will be permitted for instrument errors or inaccuracy, the method of testing or any other causes.</p> <p>The Contractor shall conduct performance test and demonstrate all the guarantees covered herein. The various tests which are to be carried out during performance guarantee tests are listed in this Sub-section. The guarantee tests shall be conducted by the Contractor at site in presence of Employer on each unit individually.</p> <p>All costs associated with the tests including cost associated with the supply, calibration, installation and removal of the test instrumentation shall be included in the contract price.</p> <p>The performance tests shall be performed using only the normal number of Employer supplied operating staff. Contractor, vendor or other subcontractor personnel shall be used only for instructional purposes or data collection. At all times during the Performance Tests the emissions and effluents from the Plant shall not exceed the Guaranteed Emission and Effluent Limits.</p> <p>It shall be responsibility of the Contractor to make the plant ready for the performance guarantee tests.</p>			
<p>LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p>SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p>PAGE 1 OF 30</p>	

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
2.02.00	<b>Test Instrumentation, Flow Measurement and their Calibration</b>			
2.02.01	<p>All instruments required for performance testing shall be of the type and accuracy required by the code and prior to the test, the Contractor shall get these instruments calibrated in an independent test Institute approved by the Employer and submit the same to Employer prior to commencement of test. All test instrumentation required for performance tests shall be supplied by the Contractor and shall be retained by him upon satisfactory completion of all such tests at site. All calibration procedures and standards shall be subject to the approval of the Employer prior to commencement of test. The protecting tubes, pressure connections and other test connections required for conducting guarantee test shall conform to the relevant codes.</p> <p>Tools and tackles, thermowells (both screwed and welded) instruments/devices including flow devices, matching flanges, impulse piping &amp; valves etc. and any special equipment, required for the successful completion of the tests, shall be provided by the Contractor free of cost.</p> <p>The Performance test shall be carried out as per the agreed procedure. The detailed PG test procedure shall be submitted within 90 days of the date of Notification of Award and finalization of the PG test procedure shall be done within 180 days from the date of Notification of Award.</p>			
2.02.02	<p>The P&amp;G test procedures shall be submitted for equipments/system &amp; subsystem under Contractor's scope for all Guarantees as mentioned below, as per latest International codes / standard including correction curves, meeting the specification requirements along with sample calculations &amp; detailed activity plan of preparation (including test instrumentation), conductance and evaluation of Guarantees.</p>			
2.02.03	<p>The Contractor shall submit for Employer's approval the detailed Performance Test procedure containing the following:</p> <ul style="list-style-type: none"> <li>(a) Object of the test.</li> <li>(b) Various guaranteed parameters &amp; tests as per contract.</li> <li>(c) Method of conductance of test and test code.</li> <li>(d) Duration of test, frequency of readings &amp; number of test runs.</li> <li>(e) Method of calculation.</li> <li>(f) Correction calculations &amp; curves.</li> <li>(g) Instrument list consisting of range, accuracy, least count, and location of instruments.</li> </ul>			
<p align="center">LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p align="center">TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p align="center">SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p align="center">PAGE 2 OF 30</p>	

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
<p>2.03.00</p> <p>2.03.01</p> <p>2.04.00</p>	<p>(h) Scheme showing measurement points.</p> <p>(i) Sample calculation.</p> <p>(j) Acceptance criteria.</p> <p>(k) Any other information required for conducting the test.</p> <p><b>Test Reports</b></p> <p>After the conductance of Performance test, the Contractor shall submit the test evaluation report of Performance test results to Employer promptly but not later than one month from the date of conductance of Performance test. Preliminary test reports shall be submitted to the Employer after completing each test run. Four (4) hard copies and two (2) soft copies on CD-ROM of each test report of final conducted test on each equipment/plant/system shall be submitted to Employer for approval.</p> <p>Performance Guarantee Tests on the equipments/systems not covered in this Sub-section shall be carried out as per the procedure/test codes specified in respective detailed specifications.</p> <p><b>Acceptance of Guarantee Test Results</b></p> <p><b>(i) For Category-I Guarantees</b></p> <p>In case during performance guarantee test(s) it is found that the equipment/system has failed to meet the guarantees, the Contractor shall carry out all necessary modifications and/or replacements to make the equipment/system comply with the guaranteed requirements at no extra cost to the Employer and re-conduct the performance guarantee test(s) with Employer's consent. In case the specified performance guarantee(s) are still not met but are achieved within the Acceptable Shortfall Limit as specified at <b>clause 3.00.00</b> of this sub-section, Employer will accept the equipment/system/plant after levying liquidated damages as per <b>clause 3.00.00</b> of this sub-section. However, if, the demonstrated performance guarantee(s) continue to be beyond the stipulated Acceptable Shortfall Limit, even after the above modifications/replacements within ninety (90) days or a reasonable period allowed by the Employer, after the tests have been completed, the Employer will have the right to either of the following:</p> <p>Reject the equipment / system / plant and recover from the Contractor the payments already made</p> <p style="text-align: center;">OR</p>			
<p>LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p>SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p>PAGE 3 OF 30</p>	

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
3.00.00	<p>Accept the equipment /system/ plant after levying Liquidated Damages. The liquidated damages for shortfall in performance indicated in clause 3.00.00 of this sub-section shall be levied separately for each unit. The rates indicated in clause 3.00.00 of this sub-section are on per unit basis for unit capacity of 500 MW. For 200 MW / 210 MW units where common absorber has been specified for two / three units based on scope of supply, LD values are applicable for combination of units as indicated in the clause 3.00.00 The liquidated damages shall be pro-rated for the fractional parts of the deficiencies.</p> <p><b>(ii) For Category-II Guarantees</b></p> <p>In case during performance guarantee test(s) it is found that the equipment/system has failed to meet the guarantees, the Contractor shall carry out all necessary modifications and/or replacements to make the equipment/system comply with the guaranteed requirements at no extra cost to the Employer and re-conduct the performance guarantee test(s) with Employer's consent. In case the specified performance guarantee(s) are still not met even after the above modifications/replacements within ninety (90) days or a reasonable period allowed by the Employer, after the tests have been completed, the Employer will have the right to either of the following:</p> <p>Reject the equipment /system / plant and recover from the Contractor the payments already made.</p> <p style="text-align: center;">OR</p> <p>Accept the equipment/system after assessing the deficiency in respect of the various ratings, performance parameters and capabilities and recover from the contract price an amount equivalent to the damages as determined by the Employer. Such damages shall, however be limited to the cost of replacement of the equipment(s)/system(s), replacement of which shall remove the deficiency so as to achieve the guaranteed performance. These parameters/capacities shall be termed as "Category-II" Guarantees.</p> <p><b>AMOUNT OF LIQUIDATED DAMAGES (LD) APPLICABLE FOR GUARANTEES FOR EACH PROJECT</b></p> <p>The rate of liquidated damages and acceptable shortfall limits for different guarantees shall be as under and such liquidated damages shall be deducted from the Contract Price of the project.</p>			
<p style="text-align: center;">LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p style="text-align: center;">TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p style="text-align: center;">SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p style="text-align: center;">PAGE 4 OF 30</p>	

CLAUSE NO.


**FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES**





**KORBA- I (3X200 MW) Common FGD system**


Sl.No	Guarantee	Rate of Liquidated Damage (LD)	Acceptable Shortfall Limit with LD
i)	<p><b>SO2 Removal Efficiency</b></p> <p>For shortfall in guaranteed SO2 removal efficiency in percentage points under conditions stipulated in clause 4.01.00 (i) of Sub-Section-VI, Part A, Section-VI.</p>	<p><b>INR 3,633,561 /-</b> (INR Three Million Six Hundred Thirty Three Thousand Five Hundred Sixty One only) for every 0.1% point shortfall in SO2 removal efficiency from the guaranteed value.</p>	<p>(-)0.25% point from the guaranteed SO2 removal efficiency.</p>
ii)	<p><b>Limestone Consumption</b></p> <p>For increase in the limestone consumption of FGD system in Kg/hr under conditions stipulated in clause 4.01.00 (ii) of Sub-Section-VI, Part A, Section-VI.</p>	<p><b>INR 20,812,843 /-</b> (INR Twenty Million Eight Hundred Twelve Thousand Eight Hundred Forty Three only) for every 100 kg/hr increase in Limestone consumption from guaranteed value.</p>	<p>(+)10% of the guaranteed limestone consumption.</p>
iii)	<p><b>Auxiliary Power Consumption</b></p> <p>For increase in the auxiliary power consumption in KW guaranteed as per the requirements of clause 4.01.00 (iii), of Sub-Section-VI, Part A, Section-VI.</p>	<p><b>INR 191,661 /-</b> (INR One Hundred Ninety One Thousand Six Hundred Sixty One only) for every KW increase in Auxiliary power consumption from the guaranteed value.</p>	<p>(+)1% of the guaranteed auxiliary power consumption</p>





CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
<p>4.00.00</p> <p>4.01.00</p>	<p><b>NOTES APPLICABLE FOR EACH PROJECT:</b></p> <ul style="list-style-type: none"> <li>i) Each of the liquidated damages specified above shall be independent and these liquidated damages shall be levied concurrently as applicable.</li> <li>ii) All these liquidated damages for short fall in performance shall be deducted from the contract price as detailed in accompanying General Conditions of Contract (GCC)/ Special Conditions of Contract (SCC)</li> <li>iii) Contractor's aggregate liability to pay Liquidated Damages (LD) for failure to attain the functional guarantee shall not exceed twenty five percent (25%) of the Contract Price.</li> <li>iv) The LD values are applicable on per unit basis for unit capacity of 500 MW. For 200 MW / 210 MW units common absorber has been specified for two / three units based on scope of supply and LD values are applicable for combination of units as indicated in the clause 3.00.00</li> </ul> <p><b>4.00.00 GUARANTEES PARAMETERS</b></p> <p><b>4.01.00 Guarantees Under Category-I</b></p> <p><b>The Performance Guarantees which attract Liquidated Damages (LD) are as follows:</b></p> <p>The following shall be guaranteed by the Bidder under guarantee point condition of Sub- Section-V, Part-A of section- VI:</p> <ul style="list-style-type: none"> <li><b>(i) SO<sub>2</sub> removal Efficiency</b></li> <p>The Contractor shall guarantee that SO<sub>2</sub> removal efficiency shall not be less than the value specified under guarantee point conditions (as specified in Clause 1.00.00/2.00.00/3.00.00 Sub-section-V, Part-A of Section-VI applicable for respective project). (To be conducted as per the stipulation of Cl. no. 6.00.00 of this sub-section.)</p> <li><b>(ii) Limestone Consumption</b></li> <p>The Contractor shall guarantee that limestone consumption of FGD system in kg/hr shall not be more than the value specified under guarantee point conditions (as specified in Clause 1.00.00/2.00.00/3.00.00 Sub-section-V, Part-A of Section-VI applicable for respective project).</p> <li><b>(iii) Auxiliary Power Consumption</b></li> <p>The Contractor shall guarantee that total auxiliary power consumption for the unit in normal operation shall not be more than the value specified under guarantee point conditions (as specified in Clause 1.00.00/2.00.00/3.00.00</p> </ul>			
<p>LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p>SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p>PAGE 21 OF 30</p>	


CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
4.02.00	<p>Sub-section-V, Part-A of Section-VI applicable for complete scope of work for the respective project), inline with the requirements stipulated in clause 5.00.00 of this Sub-Section.</p> <p><b>Guarantees Under Category-II</b></p> <p><b>The parameters/capabilities shall be demonstrated for various systems/equipments shall include but not limited to the following:-</b></p> <p><b>(i) Wet ball Mill capacity at rated fineness</b></p> <p>The contractor shall demonstrate the guaranteed capacity of each limestone pulverizer under the following conditions:</p> <p>i) Limestone Output fineness : 90% or higher (as per the requirement of the absorber) through 325 mesh (for spray tower process) (OR) 90% or higher (as per the requirement of the absorber) through 200 mesh (for bubbling process)</p> <p>ii) Limestone Quality : All available quality from the specified range.</p> <p><b>(ii) Wet ball Mill wear parts guarantee</b></p> <p>Contractor shall demonstrate the life of wet ball Mill wear parts in line with requirements stipulated in Part B of the Technical Specification. The establishment of the above guarantee shall be based on the operating records available at the Power station and will be computed for each pulverizer based on actual total hours of operation.</p> <p><b>(iii) Wet ball Mill ball consumption</b></p> <p>Contractor shall guarantee ball consumption per ton of limestone throughput in line with requirements stipulated in Part B of the Technical Specification. Contractor shall furnish the minimum ball diameter below which the balls shall be replaced.</p> <p><b>(iv) Vacuum Belt Filter Capacity</b></p> <p>Contractor shall demonstrate the Designed Capacity of the Vacuum Belt Filters to dewater the quantity of gypsum with the specified purity and moisture content as specified in Part B of the Technical Specification.</p>			
LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE	TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9	SUB-SECTION-VI FUNCTIONAL GUARANTEES & LIQUIDATED DAMAGES	PAGE 22 OF 30	

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
	<p>(v) <b>Gypsum Purity</b></p> <p>The contractor shall demonstrate that the purity of the gypsum produced shall not be less than 90%, chloride content shall not be more than 100ppm and the moisture content shall not be more than 10% for guarantee point condition.</p> <p>(vi) <b>NOT USED</b></p> <p>(vii) <b>Performance characteristics of fans (capacity, head developed, etc.).</b></p> <p>(viii) <b>Margins on fans in case Booster Fan is provided by the Contractor.</b></p> <p>Booster Fans - As specified in Part B of <b>Technical Specifications</b></p> <p>(ix) <b>Passenger cum Goods Elevator for FGD absorber &amp; Limestone Grinding Building:</b> Over load tests, travel and hoist speed checks.</p> <p>(x) <b>Noise</b></p> <p>All the plant, equipment and systems covered under this specification shall perform continuously without exceeding the noise level over the entire range of output and operating frequency specified in Part-C of Section-VI of the technical specifications.</p> <p>Noise level measurement shall be carried out using applicable and internationally acceptable standards. The measurement shall be carried out with a calibrated integrating sound level meter meeting the requirement of IEC 651 or BS 5969 or is 9779.</p> <p>Sound pressure shall be measured all around the equipment at a distance of 1.0 m horizontally from the nearest surface of any equipment/ machine and at a height of 1.5 m above the floor level in elevation.</p> <p>A minimum of 6 points around each equipment shall be covered for measurement. additional measurement points shall be considered based on the applicable standards and the size of the equipment. the measurement shall be done with slow response on the a - weighting scale. the average of a-weighted sound pressure level measurements expressed in decibels to a reference of 0.0002 micro bar shall not exceed the guaranteed value. corrections for background noise shall be considered in line with the applicable standards. all the necessary data for determining these corrections, in line with the applicable standards, shall be collected during the tests.</p>			
<p>LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p>SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p>PAGE 23 OF 30</p>	

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
	<p><b>(xi) Mist Outlet Droplet Content</b></p> <p>The mist eliminator outlet droplet content shall be guaranteed to be <math>\leq 20</math> mg/Nm<sup>3</sup> at absorber outlet measured over a period of 24 hrs continuous operation.</p> <p>Mist outlet-droplet content shall be measured as per applicable clauses in VDI Norm 3679 and the Contractor shall carry out the tests as per the test procedure approved by the Employer.</p> <p><b>(xii) Availability of FGD Plant</b></p> <p>The Contractor shall guarantee the maximum availability of FGD Plant for the range of coal and limestone specified inline with the requirements stipulated in clause 7.00.00 of this Sub-Section</p> <p><b>(xiii) Air Conditioning System</b></p> <p><b>A. Following shall be demonstrated at Shop</b></p> <p>1) Capacity and static pressure of AHU fans at its rated duty point.</p> <p><b>B. Following shall be demonstrated at Site</b></p> <p>1) Capacity (TR) of air cooled condensing units (D-X type) for A/C system of FGD control room building.</p> <p>2) Guaranteed room conditions during summer for all the Air conditioned areas.</p> <p>3) Vibration and noise level of condensing units &amp; centrifugal fans of AHUs.</p> <p><b>(xiv) Ventilation System</b></p> <p><b>A. Following shall be demonstrated at Shop</b></p> <p>1) Capacity and discharge pressure of pumps of UAF units at its rated duty point of Ventilation system.</p> <p>2) Capacity and static pressure of UAF fans at its rated duty point of Ventilation system.</p> <p><b>B. Following shall be demonstrated at Site</b></p> <p>1) Vibration &amp; Noise level of centrifugal fans &amp; pumps of UAF units.</p> <p><b>(xv) Compressed Air System</b></p> <p>a) Following shall be demonstrated at shop:</p> <p>i) Capacity and discharge pressure of each air compressor.</p> <p>b) Following shall be demonstrated at site:</p> <p>ii) Dew point of air at the outlet of air drying plants of air compressor.</p>			
<p>LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p>SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p>PAGE 24 OF 30</p>	

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES				
5.00.00	<ul style="list-style-type: none"> <li>iv) Pressure drop across air drying plant .</li> <li>v) Vibration and noise level of air compressors, blowers of air drying plant (if applicable)</li> </ul> <p><b>(xvi) Equipment Cooling Water System</b></p> <ul style="list-style-type: none"> <li>i) Vibration, noise and parallel operation without hunting &amp; abnormal noise and with flow sharing within 10% of each other at the rated duty point shall be demonstrated at site.</li> <li>ii) Design heat load of plate type heat exchangers and Inlet &amp; Outlet temperatures of the Plate type heat exchangers on the primary and secondary side to be demonstrated at site. Pressure drop across the Plate type heat exchanger on the primary &amp; secondary water circuit to be demonstrated at site.</li> </ul> <p><b>(xvii) Limestone Handling System and Gypsum Handling System</b></p> <ul style="list-style-type: none"> <li>a) Limestone Handling Plant <ul style="list-style-type: none"> <li>(i) The Bidder shall demonstrate the unloading at truck tippler, crushing and conveying to storage shed/silo and then reclaim from storage shed/silos and conveying to mill bunker at the guaranteed capacity including all intermediate equipment &amp; conveyors.</li> <li>(ii) Bidder shall also demonstrate the guaranteed tipping rate of truck tipplers.</li> </ul> </li> <li>b) Gypsum Handling Plant <p>The Bidder shall demonstrate the guaranteed conveying from belt filter to storage shed/silo including all intermediate equipment &amp; conveyors.</p> </li> </ul>				
	<p><b>AUXILIARY POWER CONSUMPTION (PA) FOR EACH PROJECT</b></p> <p>The unit auxiliary power consumption shall be calculated using the following relationship.</p> $P_a = (P_{a1} + P_{a2} + \dots + P_{an})/n$ $P_{an} = P_{un} + T_{Ln}$ <p><math>P_a</math> = Guaranteed Auxiliary Power Consumption</p> <p><math>P_{an}</math> = Auxiliary Power Consumption for unit # n</p> <p>(Where “n” is the unit number e.g. 1, 2, .....)</p>				
<p>LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p>SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p>PAGE 25 OF 30</p>		

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
	<p> <math>P_{un}</math> = Power consumed by the auxiliaries of the unit under test  <math>T_{Ln}</math> = Losses of the transformers supplied by bidder based on works test reports </p> <p>While guaranteeing the auxiliary power consumption of each project the bidder shall necessarily include all continuously operating auxiliaries under this package. The auxiliaries to be considered shall include but not be limited to the following:</p> <ol style="list-style-type: none"> <li>i. Absorber Recirculation Pump(s)/Gas Cooling Pumps</li> <li>ii. Absorber Oxidation Air Blower(s)</li> <li>iii. Absorber Oxidation Tank Agitators</li> <li>iv. Gypsum Bleed Pumps</li> <li>v. Limestone Gravimetric feeder, Wet ball mill and their integral Auxiliaries divided by the number of units in the project</li> <li>vi. Limestone Slurry Pump(s)</li> <li>vii. Vacuum Belt Filter, Vacuum Pump and its integral auxiliaries divided by the number of units in the project</li> <li>viii. Power consumption of all working Booster water pumps (if provided) to ACW pumps after PHE divided by the number of units in the project</li> <li>ix. Power consumption of Clarified water pumps (if provided) and Clarified booster water pumps (if provided) divided by the number of units in the project</li> <li>x. Power consumption of Process water pump(s) divided by the number of units in the project</li> <li>xi. Mist Eliminator Wash Water pump(s)</li> <li>xii. Power consumption of Belt Filter Wash Water Pump divided by the number of units in the project</li> <li>xiii. Power consumption of total number of DM Cooling (working) Water pump to supply cooling water on the primary (DM) side of the plate type heat exchangers in the closed loop Equipment cooling water system divided by the number of units (working) in the project</li> <li>xiv. Power consumption of total number of Auxiliary Cooling (working) water pump/Permeate water pump to supply cooling water on the secondary side</li> </ol>			
<p align="center"> <b>LOT-3 PROJECTS</b>  <b>FLUE GAS DESULPHURISATION (FGD) SYSTEM</b>  <b>PACKAGE</b> </p>	<p align="center"> <b>TECHNICAL SPECIFICATION</b>  <b>SECTION – VI, PART-A</b>  <b>BID DOC. NO.:CS-0011-109(3)-9</b> </p>	<p align="center"> <b>SUB-SECTION-VI</b>  <b>FUNCTIONAL</b>  <b>GUARANTEES &amp;</b>  <b>LIQUIDATED DAMAGES</b> </p>	<p align="center">PAGE 26 OF 30</p>	

CLAUSE NO.	FUNCTIONAL GUARANTEES AND LIQUIDATED DAMAGES			
	<p>of the plate type heat exchangers in the closed loop Equipment cooling (unit auxiliary) water system divided by the number of units (working) in the project</p> <p>xv. Booster Fans</p> <p>xvi. Power consumption of Limestone Slurry Tank Agitator(s) divided by the number of units in the project</p> <p>xvii. Power consumption of Filtrate Pump(s) divided by the number of units in the project</p> <p>xviii. Power consumption of Cloth Wash Water Pump divided by the number of units in the project</p> <p>xix. Power consumption of Hydro-cyclone and Waste Water Pump divided by the number of units in the project</p> <p>xx. Power consumption of all other continuous running Agitators divided by the number of units in the project</p> <p>xxi. Air Conditioning System (*)</p> <p>Total Power consumption at motor input terminals of working units (i.e. excluding stand-by) at its rated duty point of compressor and condenser fans of air cooled condensing unit, Air handling unit (AHU) fans for the Air conditioning system of FGD Control Room Building divided by total nos. of units in respective project</p> <p>xxii Total power consumption at motor input terminal at rated duty of fan of UAF divided by total nos. of units in respective project. (*)</p> <p>((*) Above guaranteed power consumption values shall be at 20 deg C for centrifugal fans of AHUs and at 30 deg C for centrifugal fans of UAF units and at an elevation of RL (referring to GLP of respective projects) for both AHUs and UAF centrifugal fans.)</p> <p>xxiii Total power consumption at motor input terminal at rated duty of Air compressor, Air drying plant (Heater and blower, as applicable) divided by total nos. of units in respective project.</p> <p>xxiv) Power consumption of clarified Water Pumps at rated capacity and head divided by the no of units of the project for Singrauli STPP-I &amp; II (5X200MW) &amp; (2X500MW).</p> <p>xxv) Power consumption of clarified Water Pumps at rated capacity and head divided by the no of units of the project for Farakka STPP-I (3X200MW).</p> <p>xxvi) Power consumption of clarified Water Pumps at rated capacity and head divided by the no of units of the project for Farakka STPP-II (2X500MW).</p> <p>xxvi) Power consumption of clarified Water Pumps at rated capacity and head divided by the no of units of the project for Rihand STPP-I (2X500MW).</p>			
<p>LOT-3 PROJECTS FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-A BID DOC. NO.:CS-0011-109(3)-9</p>	<p>SUB-SECTION-VI FUNCTIONAL GUARANTEES &amp; LIQUIDATED DAMAGES</p>	<p>PAGE 27 OF 30</p>	