

Analysis of limestone, water & instrument airLime-Stone:

Absorbent Name	LIMESTONE
Grain Size	Medium
Bond Index	13kWh/short-ton

Type of Absorbent	<input checked="" type="checkbox"/> Rock <input type="checkbox"/> Powder <input type="checkbox"/> Slurry <input type="checkbox"/> Others :
-------------------	---

Feed Condition to Absorber	<input type="checkbox"/> Powder <input checked="" type="checkbox"/> Slurry 30 wt% <input type="checkbox"/> Others :
----------------------------	--

Absorbent Composition		Limestone			Note
		Design	Normal	Guarantee	
CaCO ₃	wt%-d	79 (*1)	-	89 (*1)	
Dolomite(MgCa(CO ₃) ₂)	wt%-d	0	-	0	
Inert	CaO	wt%-d	47-51.0 (*1)	-	-
	MgO	wt%-d	0.9-2.0	-	-
	Cl ₂	wt%-d	<0.015	-	-
	Al ₂ O ₃	wt%-d	1.19-2.1	-	-
	Si ₂ O ₃	wt%-d	2.1-4.5	-	-
	Fe ₂ O ₃	wt%-d	0.45-1.0	-	-
	TiO ₂	wt%-d	<0.02	-	-
	Na ₂ O	wt%-d	<0.16	-	-
	K ₂ O	wt%-d	<0.01	-	-
	P ₂ O ₅	wt%-d	Traces	-	-
	LOI	wt%-d	39.0-41.3	-	-
	Total Sulphur	wt%-d	<0.1	-	-
Mn ₂ O ₃	wt%-d	<0.12	-	-	
Density	kg/m ³	1400			For volume
	kg/m ³	1700			For torque, drive calculation and structural load calculation

N/D : Not detectable

(*1) Design condition limestone purity CaCO₃ 79%; Guarantee condition limestone purity CaCO₃ 89%

Process Water:

		CW Blowdown (*1)		
		Minimum	Normal	Maximum
Temperature at B.L.	deg.C		27	45
Pressure at B.L.	MPaG	-	-	-
pH	-	-	7.8-8.2	-
S.S.	mg/l	-	-	-
Composition				
Ca ²⁺	ppm CO ₃ Ca	-	153.6	-
Mg ²⁺	ppm CO ₃ Ca	-	42	-
Na ⁺	ppm CO ₃ Ca	-	75	-
K ⁺	ppm CO ₃ Ca	-		-
Oil and Grease	mg/l	-	-	-
N ₂ H ₄	mg/l	-	-	-
HCO ₃ ⁻	ppm CO ₃ Ca	-	-	-
CO ₃ ²⁻	ppm CO ₃ Ca	-	-	-
Cl ⁻	ppm CO ₃ Ca	-	45	-
SO ₄ ²⁻	ppm CO ₃ Ca	-	118.5	-
Silica	mg/l	-	33	-
To-NH ₄	mg/l	-	-	-
Fe ²⁺	mg/l	-	1	-
Cd	mg/l	-	-	-
NO ₃ ⁻	ppm CO ₃ Ca	-	-	-
B	mg/l	-	-	-
To-Inorganic	mg/l	-	-	-
Cu	microg/l	-	-	-
Hg	microg/l	-	-	-
Pb	microg/l	-	-	-
NO ₂ ⁻	microg/l	-	-	-
F ⁻	microg/l	-	-	-
Cr ²⁺	microg/l	-	-	-
Ni	microg/l	-	-	-
To-Zn	microg/l	-	-	-
BOD5	mg/l	-	-	-
COD Cr	mg/l	-	-	-
Total alkalinity	ppm CO ₃ Ca	-	107.1	-
Total Hardness	ppm CO ₃ Ca	-	-	-
Turbidity	NTU	-	60	-
Conductivity	micro m/m	-	-	-

(*1) Raw water Analysis is taken from tender documents (Part A-Section VI - Sub section II-A4)

Cooling Water

Water Source		DM Water					
		Available Value			Design Value		
		Minimum	Normal	Maximum	Minimum	Normal	Maximum
Supply Temp. at TP	deg.C	-	-	-	-	35	-
Return Temp. at TP	deg.C	-	-	-	-	45	-
ΔT	deg.C	-	-	-	-	10	-
Supply Press. at TP	MPaG	-	-	-	-	0.6(*1)	-
Return Press. at TP	MPaG	-	-	-	-	0.3(*1)	-

(*1) Assumed value

Instrument Air:

Air Source		-					
Dew Point (atmospheric)	deg.C	≤ -40					
Oil Mist Contamination		<input type="checkbox"/> Contaminated <input checked="" type="checkbox"/> Not Contaminated					
		Available Value			Design Value		
		Minimum	Normal	Maximum	Minimum	Normal	Maximum
Temperature at TP	deg.C	-	-	-	-	45(*1)	-
Pressure at TP	MPaG	-	-	-	0.55	-	0.8

(*1) In summer

Service Air

Air Source		-					
		Available Value			Design Value		
		Minimum	Normal	Maximum	Minimum	Normal	Maximum
Temperature at TP	deg.C	-	-	-	-	45(*1)	-
Pressure at TP	MPaG	-	-	-	0.55	-	0.8

(*1) In summer